

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman

FROM: Thomas Lucchesi, Asst. Fire Inspector

SUBJECT: PB-08-09
Woodlawn Manor
SBL: 26-1-1.1,26-1-1.2, 40-2-8,44-1-14

DATE: July 2, 2008

Fire Prevention Reference Number: FPS-08-023

A review of the above referenced site plan has been conducted and is not acceptable for the following reasons:

- 1) Emergency access road shall be 20'
FC 503.2.1**
- 2) Cul de sac rear building 3 width shall be 20'
FC 503.2.1**
- 3) Main entrance road shall be 20' width each
side of the Island.**